



<b>Certificate of conformity Power generation unit</b>		<b>Nr: 2015 -1519</b> Signed copy No. 1
<b>Manufacturer</b>	Steca Elektronik GmbH	
<b>Type Power generation unit</b>	Turbo 3P1, Turbo 3P2	
<b>Assessment values</b>	max. active power $P_{E_{max}}$	4,0 / 6,2 kW
	max. apparent power $S_{E_{max}}$	4,0 / 6,2 kW
	Rated voltage	230 V
<b>Network connection rule</b>	<b>VDE-AR-N 4105</b> <b>„Power generation system connected to the low-voltage grid“</b> Technical minimum requirements for connection and parallel operation of power generation systems connected to the low-voltage grid	
The above mentioned power generation unit meets the requirements of VDE-AR-N 4105.		
<p>It is hereby confirmed that the specific requirements of VDE-AR-N 4105 have been tested.</p> <p>VDE-AR-N 4105 compliance is guaranteed in all inverters with firmware Net13_ENS_APP_0_26_0.upd or higher.</p>		
Memmingen, 08.04.2015	Steca Elektronik GmbH ppa. Ralf Griepentrog	
This certificate of conformity shall not be used in parts.		
 Steca Elektronik GmbH Mammostraße 1 87700 Memmingen service@stecasolar.com		