

**Certificate of conformity  
Power generation unit**

Nr: 2016 –1608

**Manufacturer**

Steca Elektronik GmbH

**Type Power generation unit**

Turbo 1P Mini, Turbo 1P

**Assessment values**

max. active power  $P_{E_{max}}$

2,0 / 4,2 kW

max. apparent power  $S_{E_{max}}$

2,0 / 4,2 kW

Rated voltage

230 V

**Network connection rule**

**VDE-AR-N 4105**

**„Power generation system connected to the low-voltage grid“**

Technical minimum requirements for connection and parallel operation of power generation systems connected to the low-voltage grid

The above mentioned power generation unit meets the requirements of VDE-AR-N 4105.

It is hereby confirmed that the specific requirements of VDE-AR-N 4105 have been tested.

VDE-AR-N 4105 compliance is guaranteed in all inverters with firmware "NET11\_ENS\_3.51" or higher.

Memmingen, 07.03.2016

Steca Elektronik GmbH

ppa. Ralf Griepentrog

This certificate of conformity shall not be used in parts.



Steca Elektronik GmbH  
Mammostraße 1  
87700 Memmingen  
service@stecasolar.com

